

RESIDENTIAL SWIMMING POOL SAFETY REGULATION COMPLIANCE ASSESSMENT FORM

This form will enable you to assess whether your current or proposed installation complies with the Residential Swimming Pool Safety Regulation. Consider contacting your municipality once you have completed this form. Your municipality is responsible for enforcing the Regulation. Specific rules may apply within the municipality's jurisdiction. Furthermore, a municipal permit is required to install a pool, diving board or any construction giving or preventing access to a pool (enclosure, platform, deck opening onto the pool).

For more information, please refer to the [Ministère's website](#) for explanatory documents on the applicable standards.

ABOVE GROUND POOL WITH A WALL HEIGHT OF AT LEAST 1.2 M



ABOVE GROUND POOL WITH A WALL HEIGHT OF AT LEAST 1.2 M

To validate your installations' compliance, you must have checked "Yes" to all applicable questions.

Subject	Question	Yes	No	Not Applicable
CONTROL OF ACCESS	<p>If my pool is secured with a surrounding enclosure, does it have the following characteristics:</p> <ul style="list-style-type: none"> • it is at least 1.2 m in height? • it prevents the passage of a spherical object 10 cm in diameter (between the bars, between the bottom of the fence and the ground)? • it is free of fixtures, projections or open parts enabling it to be climbed? • if it is a chain-link fence, the mesh is 30 mm or less in width or, if not, is the fence slatted? <p>This requirement only applies to chain link fences installed on or after July 1, 2021. However, a chain-link fence acquired before July 1, 2021, but installed on or before September 30, 2021, is also exempt from this requirement.</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>If my pool is accessed from a removable ladder, is the ladder equipped with a self-closing and self-latching safety gate?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>If my pool is accessed from a platform, is it secured with an enclosure that complies with all enclosure requirements (see question one)?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>If my pool is accessed from a deck attached to the residence, is the portion of the deck that opens to the pool secured with an enclosure that complies with all the requirements for an enclosure (see first question)?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
ENCLOSURE GATE Complete this section only if your installations include an enclosure equipped with a gate.	<p>Is the enclosure gate at least 1.2 m in height?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>When closed, does the enclosure gate prevent the passage of a spherical object 10 cm in diameter (between the bars, between the bottom of the fence and the ground)?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>Is the enclosure gate free of fixtures, projections or open parts enabling it to be climbed?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>Is the enclosure gate self-closing and self-latching?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	<p>If the passive security device (latch) is located on the inside of the enclosure, is it located at the top of the gate?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<p>If the passive safety device (latch) is located on the outside of the enclosure, is it located at a minimum of 1.5 m in height?</p>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Subject	Question	Yes	No	Not	Applicable
<p>WALL FORMING PART OF AN ENCLOSURE</p> <p>Complete this section only if the wall of a building (house, garage) forms part of the enclosure surrounding your pool.</p>	<p>Is the wall that forms part of the enclosure without a gate?</p>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
	<p>If the wall that forms part of the enclosure has a window, is it at least 3 m from the ground or, if not, does it have a maximum opening that prevents the passage of a spherical object that is larger than 10 cm in diameter?</p>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
<p>FACILITIES AROUND THE POOL</p> <p>In the case of a pool surrounded by an enclosure, these requirements apply to the exterior sides of the enclosure.</p>	<p>Are the devices that are linked to the operation of my pool (e.g., a filter) located in any of the following areas:</p> <ul style="list-style-type: none"> • at more than 1 m from the pool wall? • under a structure (e.g., deck) that is at least 1.2 m in height and cannot be easily climbed? • in a shed? • within an enclosure that complies with all the requirements for an enclosure (see the first section)? 	<input type="checkbox"/>	<input type="checkbox"/>		
	<p>Is the area around my pool clear for at least 1 m of any structure or fixed equipment that could be used to climb over the enclosure (e.g. retaining wall, children’s play structure)?</p> <p>This requirement only applies to pools installed on or after July 1, 2021. However, an enclosure acquired before July 1, 2021, but installed on or before September 30, 2021, is also exempt from this requirement.</p>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>
	<p>Is my pool located at least 1 m from any building window? If not, is the window at least 3 m from the ground, or does the window have a maximum opening that prevents the passage of a spherical object that is larger than 10 cm in diameter?</p> <p>This requirement only applies to pools installed on or after July 1, 2021. However, an enclosure acquired before July 1, 2021, but installed on or before September 30, 2021, is also exempt from this requirement.</p>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>